

# SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1412

Dated: 16-10-2023

It is certified that an inspection team headed by .....Pankaj Kumar and Jagdeep.....  
from Jal Shakati Vibhag Sub- Division Jhandutta, Himachal Pradesh inspected the  
**SHIVA GURUKUL INTERNATIONAL SCHOOL JHANDUTTA, Distt. Bilaspur (HP)**  
on ~~09.10.2023~~ and on the basis of Water Test Report (Attached) bearing no.  
JSV-JSD-Water sample/2023/412 dated: 09/10/2023 of Jal Shakti Sub Divisional Laboratory  
Jhandutta certified that the SHIVA GURUKUL INTERNATIONAL SCHOOL JHANDUTTA has  
safe drinking water facilities for the students and members of staff of the institution.  
School is also maintaining the hygienic sanitation condition in the school building & the  
campus as per norms prescribed by the State Govt.

Signature with Seal: [Signature] 16.10.2023

Name : Aman Takur Assistant Engineer  
Jal Shakti Sub Division  
Jhandutta

Designation : ADO Civil

Jal Shakati Vibhag Sub- Division Jhandutta

**Certificate issued to:**

✓ The Principal  
Shiva Gurukul International School  
Jhandutta (Bilaspur) H.P.

HIMACHAL PRADESH  
JAL SHAKTI VIBHAG

JAL SHAKTI SUB DIVISIONAL LABORATORY JHANDUTTA  
TEST REPORT ON PHYSICAL, CHEMICAL & BACTERIOLOGICAL EXAMINATION

Sample No.	Date:- 09/10/2023
TEST REPORT NO.	Condition of sample when received ok
Name and address of customer: The Principal	Name of source/scheme WSS Jhandutta Schmn
Sampling Method: Shiva Gurukul International School	Name of Panchayat Jhandutta
Sample Description: - Jhandutta	Name of Habitation Jhandutta
Sample Quantity: 1Ltr.	Name of village Jhandutta
Collected on: 09/10/2023	Type of Source Scasched
Test start Date: -do-	Shiva Gurukul International School
Test End Date: -do-	Jhandutta

Sr.N	TEST PARAMETER	UNITS	RESULT	Acceptable limit	Permissible limit in absence of alternate source	TEST METHOD
1	Colour	Hazen	5	5	15	IS 3025 (Part-4)
2	Odour	-	Agreeable	-	-	IS 3025 (Part-5)
3	Taste	-	Agreeable	-	-	IS 3025(Part 7 & 8)
4	pH	-	7.38	6.5	8.5	IS 3025 (Part 11)
5	TDS	Mg/l	275	500	2000	IS 3025(PART 16)
6	Total Alkalinity as CaCO3	Mg/l	288	200	600	IS 3025 (Part 23)
7	Total Hardness as CaCO3	Mg/l	184	200	600	IS 3025(Part 21)
8	Chloride	Mg/l	48.28	250	1000	IS 3025(Part 32)
9	Turbidity	NTU	1.5	1	5	IS 3025(Part 10)
10	Calcium (as Ca)	Mg/l	49.6	75	200	IS 3025 (Part-40)
11	Magnesium (as Mg)	Mg/l	14.58	30	100	IS 3025 (Part-46)
12	Total Coliform	MPN	NIL	-	-	MPN
13	Residual Chlorine	-	0.3	0.2	1	

Remarks:- This water sample is safe for drinking purpose.

Note:-

- \*This report should not be produced partly or full without approval of signatory authority for legal purpose.
- \*The result refers only to tested samples and parameters tested.
- \*Samples will be stored for a period of 7 days from the date of issue of report

psharma  
Tested by

psharma  
Technical Manager  
Water testing Laboratory Jhandutta

Assistant Engineer  
Authorized Signatory  
Jal Shakti Sub Division  
Jhandutta